

CERTIFICATE OF COMPLIANCE
Mueller Post Indicators


WE HEREBY CERTIFY that MUELLER CO. Post Indicators are approved by the independent agencies noted in the chart below.

Indicator Post Approvals			
Model No.	Description	Valve Size	Approvals
A20806	Adjustable	4-14"	UL 789, FM 1110
A20807	Adjustable	16-24"	UL 789
A20808	Non-Adjustable	4-14"	UL 789, FM 1110
A20809	Non-Adjustable	16-24"	UL 789
A20814	Wall Mount	4-14"	UL 789, FM 1110

Post Indicators are manufactured at the Mueller ISO 9001 registered facility in Albertville, Alabama, USA. Component manufacturing and assembly is performed in accordance with Mueller QA and associated manufacturing procedures which include but are not limited to relevant dimensional, visual, and functional inspection and verification.

Mueller certifies that post indicator head and bell castings are manufactured per Mueller QA procedures; each heat is tested and certified to be within the specification shown in the chart under a controlled program and in accordance with ASTM A126 Class B Gray Iron or ASTM A536 Ductile Iron as applicable.

Sincerely,



Alan Channell
Product Manager
Mueller Company
Water Products Division
www.muellercompany.com



January 2017